

## FINAL REPORT

### Albany Memorial Hospital

Engineering  
 600 Northern Blvd  
 Albany, NY 12204  
 P: (518) 471-3015  
 F: (518) 447-3587  
**ATTN:** Larry Tilton

**Account #:** 2318  
 SPL Project ID: 1803-00174  
 Project Name: Water Samples For Leg.  
 PO Number: 3226-4019  
 Sampled By: Tom Poole  
 Date Received: 03/07/2018  
 Date Final: 03/14/2018

## Summary

This summary is provided for your convenience. Complete report on the following pages.

### General Comments:

Water Samples For Legionella Testing

### Legionella Environmental Culture Test – New York

Location	Result	Concentration
1. 5 South Sink	Not Detected	
2. 5 North Shower	Not Detected	
3. 3 South Ex Rm 2	Not Detected	
4. 3 North Sink	Not Detected	
5. 4 South Sink	Not Detected	
6. 4 North Shower	Not Detected	
7. 4 CCD 438.02	Not Detected	
8. 4 CCD 440.01	Not Detected	
9. 2 North Sink	Not Detected	
10. 2 South Shower	Not Detected	
11. ED Across from Ex Rm 3	Not Detected	
12. SG Return	Not Detected	

Approved by: Sue Mietzner



Janet E. Stout, Ph.D.  
 Director, Special Pathogens Laboratory

## FINAL REPORT

### Albany Memorial Hospital

Engineering  
 600 Northern Blvd  
 Albany, NY 12204  
 P: (518) 471-3015  
 F: (518) 447-3587  
**ATTN:** Larry Tilton

**Account #:** 2318  
 SPL Project ID: 1803-00174  
 Project Name: Water Samples For Leg.  
 PO Number: 3226-4019  
 Sampled By: Tom Poole  
 Date Received: 03/07/2018  
 Date Final: 03/14/2018

Location:	<b>1. 5 South Sink</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.001	Sample Type:	Water
		Time Collected:	7:30 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/14/2018
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>2. 5 North Shower</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.002	Sample Type:	Water
		Time Collected:	7:41 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/14/2018
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>3. 3 South Ex Rm 2</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.003	Sample Type:	Water
		Time Collected:	7:51 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/14/2018
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>4. 3 North Sink</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.004	Sample Type:	Water
		Time Collected:	8:03 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/14/2018
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>5. 4 South Sink</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.005	Sample Type:	Water
		Time Collected:	8:15 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/14/2018
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>6. 4 North Shower</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.006	Sample Type:	Water
		Time Collected:	8:20 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/14/2018
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

## FINAL REPORT

### Albany Memorial Hospital

Engineering  
 600 Northern Blvd  
 Albany, NY 12204  
 P: (518) 471-3015  
 F: (518) 447-3587  
**ATTN:** Larry Tilton

**Account #:** 2318  
**SPL Project ID:** 1803-00174  
**Project Name:** Water Samples For Leg.  
**PO Number:** 3226-4019  
**Sampled By:** Tom Poole  
**Date Received:** 03/07/2018  
**Date Final:** 03/14/2018

Location:	<b>7. 4 CCD 438.02</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.007	Sample Type:	Water
		Time Collected:	8:30 am

Test Requested: Legionella Environmental Culture Test – New York      Status: Complete 03/14/2018  
 Result: **Not Detected**  
 Volume Examined: 0.1 mL of processed sample

Location:	<b>8. 4 CCD 440.01</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.008	Sample Type:	Water
		Time Collected:	8:32 am

Test Requested: Legionella Environmental Culture Test – New York      Status: Complete 03/14/2018  
 Result: **Not Detected**  
 Volume Examined: 0.1 mL of processed sample

Location:	<b>9. 2 North Sink</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.009	Sample Type:	Water
		Time Collected:	8:40 am

Test Requested: Legionella Environmental Culture Test – New York      Status: Complete 03/14/2018  
 Result: **Not Detected**  
 Volume Examined: 0.1 mL of processed sample

Location:	<b>10. 2 South Shower</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.010	Sample Type:	Water
		Time Collected:	8:50 am

Test Requested: Legionella Environmental Culture Test – New York      Status: Complete 03/14/2018  
 Result: **Not Detected**  
 Volume Examined: 0.1 mL of processed sample

Location:	<b>11. ED Across from Ex Rm 3</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.011	Sample Type:	Water
		Time Collected:	9:05 am

Test Requested: Legionella Environmental Culture Test – New York      Status: Complete 03/14/2018  
 Result: **Not Detected**  
 Volume Examined: 0.1 mL of processed sample

Location:	<b>12. SG Return</b>	Date Collected:	03/06/2018
Sample ID:	1803-00174.012	Sample Type:	Water
		Time Collected:	9:10 am

Test Requested: Legionella Environmental Culture Test – New York      Status: Complete 03/14/2018  
 Result: **Not Detected**  
 Volume Examined: 0.1 mL of processed sample

## FINAL REPORT

### Albany Memorial Hospital

Engineering  
600 Northern Blvd  
Albany, NY 12204  
P: (518) 471-3015  
F: (518) 447-3587  
**ATTN:** Larry Tilton

**Account #:** 2318  
SPL Project ID: 1803-00174  
Project Name: Water Samples For Leg.  
PO Number: 3226-4019  
Sampled By: Tom Poole  
Date Received: 03/07/2018  
Date Final: 03/14/2018

Approved by: Sue Mietzner



Janet E. Stout, Ph.D.  
Director, Special Pathogens Laboratory

## NOTES

### Legionella Environmental Culture Test - New York

- CFU/mL = Colony Forming Units per milliliter of sample
- Limit of detection (LOD): 10 CFU/mL for hot water tanks and non-potable water (cooling towers); 1-10 CFU/mL for potable water. If less than recommended volume is concentrated, sensitivity may be affected. If liter sample is processed, the LOD is <1 CFU/mL.
- Results are reported as Not Detected, Positive, or Uninterpretable.
- Uninterpretable result is due to culture overgrowth by non-Legionella bacteria
- Method: ISO 11731:2017 (E). QA/QC performed on the date processed. Turnaround time is 7-10 days.
- Certified for Legionella culture analysis by New York State Department of Health ELAP. ELAP lab ID no.12024
- Isolates saved upon request. Request must be received 1 week from receipt of report. Additional charges may apply.
- On receipt, SPL lab checks samples for chlorine neutralization by sodium thiosulfate in the collection bottles. Neutralization of other biocides that may be present is not checked.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL.