

## FINAL REPORT

### Albany Memorial Hospital

Engineering  
600 Northern Blvd  
Albany, NY 12204  
P: (518) 471-3015  
F: (518) 447-3587  
**ATTN:** Larry Tilton

**Account #:** 2318  
SPL Project ID: 1805-00307  
Project Name: Water Samples Leg Testing  
PO Number: 3226-4019  
Sampled By: TR. Poole  
Date Received: 05/09/2018  
Date Final: 05/16/2018

## Summary

This summary is provided for your convenience. Complete report on the following pages.

### Legionella Environmental Culture Test – New York

Location	Result	Concentration
1. MOB Tower	Not Detected	
2. Main Tower	Not Detected	

Approved by: Brian Verdi



Janet E. Stout, Ph.D.  
Director, Special Pathogens Laboratory

## FINAL REPORT

### Albany Memorial Hospital

Engineering  
600 Northern Blvd  
Albany, NY 12204  
P: (518) 471-3015  
F: (518) 447-3587  
**ATTN:** Larry Tilton

**Account #:** 2318  
SPL Project ID: 1805-00307  
Project Name: Water Samples Leg Testing  
PO Number: 3226-4019  
Sampled By: TR. Poole  
Date Received: 05/09/2018  
Date Final: 05/16/2018

Location:	<b>1. MOB Tower</b>	Date Collected:	05/08/2018
Sample ID:	1805-00307.001	Sample Type:	Water
		Time Collected:	7:30 am
Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 05/16/2018
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>2. Main Tower</b>	Date Collected:	05/08/2018
Sample ID:	1805-00307.002	Sample Type:	Water
		Time Collected:	7:40 am
Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 05/16/2018
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Approved by: Brian Verdi



Janet E. Stout, Ph.D.  
Director, Special Pathogens Laboratory

## NOTES

### Legionella Environmental Culture Test - New York

- CFU/mL = Colony Forming Units per milliliter of sample
- Limit of detection (LOD): 10 CFU/mL for hot water tanks and non-potable water (cooling towers); 1-10 CFU/mL for potable water. If less than recommended volume is concentrated, sensitivity may be affected. If liter sample is processed, the LOD is <1 CFU/mL.
- Results are reported as Not Detected, Positive, or Uninterpretable.
- Uninterpretable result is due to culture overgrowth by non-Legionella bacteria
- Method: ISO 11731:2017 (E). QA/QC performed on the date processed. Turnaround time is 7-10 days.
- Certified for Legionella culture analysis by New York State Department of Health ELAP. ELAP lab ID no.12024
- Isolates saved upon request. Request must be received 1 week from receipt of report. Additional charges may apply.
- On receipt, SPL lab checks samples for chlorine neutralization by sodium thiosulfate in the collection bottles. Neutralization of other biocides that may be present is not checked.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL.