

FINAL REPORT

Albany Memorial Hospital

Engineering
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1806-00935
Project Name: Water Samples Leg
PO Number: 3226-4019
Sampled By: Tom Poole
Date Received: 06/28/2018
Date Final: 07/05/2018

Summary

This summary is provided for your convenience. Complete report on the following pages.

Legionella Environmental Culture Test – New York

Location	Result	Concentration
1. Main-Cooling Tower	Not Detected	
2. Mob-Cooling Tower	Not Detected	

Approved by: Brian Verdi



Janet E. Stout, Ph.D.
Director, Special Pathogens Laboratory

FINAL REPORT

Albany Memorial Hospital

Engineering
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1806-00935
Project Name: Water Samples Leg
PO Number: 3226-4019
Sampled By: Tom Poole
Date Received: 06/28/2018
Date Final: 07/05/2018

Location:	1. Main-Cooling Tower	Date Collected:	06/27/2018
Sample ID:	1806-00935.001	Sample Type:	Water
		Time Collected:	1:10 pm
Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 07/05/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	2. Mob-Cooling Tower	Date Collected:	06/27/2018
Sample ID:	1806-00935.002	Sample Type:	Water
		Time Collected:	1:15 pm
Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 07/05/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Approved by: Brian Verdi



Janet E. Stout, Ph.D.
Director, Special Pathogens Laboratory

NOTES

Legionella Environmental Culture Test - New York

- CFU/mL = Colony Forming Units per milliliter of sample
- Limit of detection (LOD): 10 CFU/mL for hot water tanks and non-potable water (cooling towers); 1-10 CFU/mL for potable water. If less than recommended volume is concentrated, sensitivity may be affected. If liter sample is processed, the LOD is <1 CFU/mL.
- Results are reported as Not Detected, Positive, or Uninterpretable.
- Uninterpretable result is due to culture overgrowth by non-Legionella bacteria
- Method: ISO 11731:2017 (E). QA/QC performed on the date processed. Turnaround time is 7-10 days.
- Certified for Legionella culture analysis by New York State Department of Health ELAP. ELAP lab ID no.12024
- Isolates saved upon request. Request must be received 1 week from receipt of report. Additional charges may apply.
- On receipt, SPL lab checks samples for chlorine neutralization by sodium thiosulfate in the collection bottles. Neutralization of other biocides that may be present is not checked.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL.