

FINAL REPORT

Albany Memorial Hospital

Engineering
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1808-00631
Project Name: Water Samples for Leg.
PO Number: 3226-4019
Sampled By: Tom Poole
Date Received: 08/16/2018
Date Final: 08/23/2018

Summary

This summary is provided for your convenience. Complete report on the following pages.

General Comments:

Water Samples for Legionella Testing

Legionella Environmental Culture Test – New York

Location	Result	Concentration
1. AMH Main Cooling Tower	Not Detected	
2. AMH Med Office Building	Not Detected	

Approved by: Marisa Hirsh



Janet E. Stout, Ph.D.
Director, Special Pathogens Laboratory

FINAL REPORT

Albany Memorial Hospital

Engineering
 600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
 SPL Project ID: 1808-00631
 Project Name: Water Samples for Leg.
 PO Number: 3226-4019
 Sampled By: Tom Poole
 Date Received: 08/16/2018
 Date Final: 08/23/2018

Location:	1. AMH Main Cooling Tower	Date Collected:	08/14/2018
Sample ID:	1808-00631.001	Sample Type:	Water
		Time Collected:	10:10 am
Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 08/23/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	2. AMH Med Office Building	Date Collected:	08/14/2018
Sample ID:	1808-00631.002	Sample Type:	Water
		Time Collected:	10:20 am
Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 08/23/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Approved by: Marisa Hirsh



Janet E. Stout, Ph.D.
 Director, Special Pathogens Laboratory

NOTES

Legionella Environmental Culture Test - New York

- CFU/mL = Colony Forming Units per milliliter of sample
- Limit of detection (LOD): 10 CFU/mL for hot water tanks and non-potable water (cooling towers); 1-10 CFU/mL for potable water. If less than recommended volume is concentrated, sensitivity may be affected. If liter sample is processed, the LOD is <1 CFU/mL.
- Results are reported as Not Detected, Positive, or Uninterpretable.
- Uninterpretable result is due to culture overgrowth by non-Legionella bacteria
- Method: ISO 11731:2017 (E). QA/QC performed on the date processed. Turnaround time is 7-10 days.
- Certified for Legionella culture analysis by New York State Department of Health ELAP. ELAP lab ID no.12024
- Isolates saved upon request. Request must be received 1 week from receipt of report. Additional charges may apply.
- On receipt, SPL lab checks samples for chlorine neutralization by sodium thiosulfate in the collection bottles. Neutralization of other biocides that may be present is not checked.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL.