

FINAL REPORT

Albany Memorial Hospital

Engineering
 600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1809-00083
Project Name: Water Samples for Leg
PO Number: 3226-4019
Sampled By: Thomas Poole
Date Received: 09/06/2018
Date Final: 09/13/2018

Summary

This summary is provided for your convenience. Complete report on the following pages.

Legionella Environmental Culture Test – New York

Location	Result	Concentration
1. MOB Cooling Tower	Not Detected	
2. Main Cooling Tower	Not Detected	
3. 5N – Shower	Not Detected	
4. 5S – Sink	Not Detected	
5. 4N– Shower	Not Detected	
6. 4S – Sink	Not Detected	
7. 4 CCD 438-01	Not Detected	
8. 4 CCD 440.1	Not Detected	
9. 3N – Sink	Not Detected	
10. 3S – Ex Rm 7	Not Detected	
11. 2N – Sink	Not Detected	
12. ED XE3	Not Detected	

Approved by: Jack Rihs



Janet E. Stout, Ph.D.
 Director, Special Pathogens Laboratory

FINAL REPORT

Albany Memorial Hospital

Engineering
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1809-00083
Project Name: Water Samples for Leg
PO Number: 3226-4019
Sampled By: Thomas Poole
Date Received: 09/06/2018
Date Final: 09/13/2018

Location:	1. MOB Cooling Tower	Date Collected:	09/05/2018
Sample ID:	1809-00083.001	Sample Type:	Water
		Time Collected:	10:00 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	2. Main Cooling Tower	Date Collected:	09/05/2018
Sample ID:	1809-00083.002	Sample Type:	Water
		Time Collected:	10:05 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	3. 5N – Shower	Date Collected:	09/05/2018
Sample ID:	1809-00083.003	Sample Type:	Water
		Time Collected:	10:15 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	4. 5S – Sink	Date Collected:	09/05/2018
Sample ID:	1809-00083.004	Sample Type:	Water
		Time Collected:	10:20 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	5. 4N- Shower	Date Collected:	09/05/2018
Sample ID:	1809-00083.005	Sample Type:	Water
		Time Collected:	10:25 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	6. 4S – Sink	Date Collected:	09/05/2018
Sample ID:	1809-00083.006	Sample Type:	Water
		Time Collected:	10:30 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

FINAL REPORT

Albany Memorial Hospital

Engineering
 600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
 SPL Project ID: 1809-00083
 Project Name: Water Samples for Leg
 PO Number: 3226-4019
 Sampled By: Thomas Poole
 Date Received: 09/06/2018
 Date Final: 09/13/2018

Location:	7. 4 CCD 438-01	Date Collected:	09/05/2018
Sample ID:	1809-00083.007	Sample Type:	Water
		Time Collected:	10:35 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	8. 4 CCD 440.1	Date Collected:	09/05/2018
Sample ID:	1809-00083.008	Sample Type:	Water
		Time Collected:	10:40 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	9. 3N – Sink	Date Collected:	09/05/2018
Sample ID:	1809-00083.009	Sample Type:	Water
		Time Collected:	10:45 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	10. 3S – Ex Rm 7	Date Collected:	09/05/2018
Sample ID:	1809-00083.010	Sample Type:	Water
		Time Collected:	10:50 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	11. 2N – Sink	Date Collected:	09/05/2018
Sample ID:	1809-00083.011	Sample Type:	Water
		Time Collected:	10:55 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	12. ED XE3	Date Collected:	09/05/2018
Sample ID:	1809-00083.012	Sample Type:	Water
		Time Collected:	11:00 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 09/13/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

FINAL REPORT

Albany Memorial Hospital

Engineering
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1809-00083
Project Name: Water Samples for Leg
PO Number: 3226-4019
Sampled By: Thomas Poole
Date Received: 09/06/2018
Date Final: 09/13/2018

Approved by: Jack Rihs



Janet E. Stout, Ph.D.
Director, Special Pathogens Laboratory

NOTES

Legionella Environmental Culture Test - New York

- CFU/mL = Colony Forming Units per milliliter of sample
- Limit of detection (LOD): 10 CFU/mL for hot water tanks and non-potable water (cooling towers); 1-10 CFU/mL for potable water. If less than recommended volume is concentrated, sensitivity may be affected. If liter sample is processed, the LOD is <1 CFU/mL.
- Results are reported as Not Detected, Positive, or Uninterpretable.
- Uninterpretable result is due to culture overgrowth by non-Legionella bacteria
- Method: ISO 11731:2017 (E). QA/QC performed on the date processed. Turnaround time is 7-10 days.
- Certified for Legionella culture analysis by New York State Department of Health ELAP. ELAP lab ID no.12024
- Isolates saved upon request. Request must be received 1 week from receipt of report. Additional charges may apply.
- On receipt, SPL lab checks samples for chlorine neutralization by sodium thiosulfate in the collection bottles. Neutralization of other biocides that may be present is not checked.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL.