

FINAL REPORT

Albany Memorial Hospital

Engineering
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1812-00291
Project Name: Water Samples For Leg.
PO Number: 3226-4019
Sampled By: Thomas R. Poole
Date Received: 12/13/2018
Date Final: 12/20/2018

Summary

This summary is provided for your convenience. Complete report on the following pages.

General Comments:

Water Samples for Legionella Testing

Legionella Environmental Culture Test – New York

Location	Result	Concentration
1. 6th Fl – 619	Not Detected	
2. 6th Fl – WR	Not Detected	
3. 4N – Shower	Not Detected	
4. 4S – COR Sink	Not Detected	
5. 4 – CCD – 438.01	Not Detected	
6. 4 – CCD – 440.01	Not Detected	
7. 3N – COR Sink	Not Detected	
8. 3S – Ex Rm 1	Not Detected	
9. 2N – COR Sink	Not Detected	
10. ED XR16	Not Detected	
11. SG Return	Not Detected	
12. Main CT	Not Detected	

Approved by: Jack Rihs



Janet E. Stout, Ph.D.
Director, Special Pathogens Laboratory

FINAL REPORT

Albany Memorial Hospital

Engineering
 600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1812-00291
Project Name: Water Samples For Leg.
PO Number: 3226-4019
Sampled By: Thomas R. Poole
Date Received: 12/13/2018
Date Final: 12/20/2018

Location:	1. 6th Fl – 619	Date Collected:	12/12/2018
Sample ID:	1812-00291.001	Sample Type:	Water
		Time Collected:	7:55 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	2. 6th Fl – WR	Date Collected:	12/12/2018
Sample ID:	1812-00291.002	Sample Type:	Water
		Time Collected:	8:05 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	3. 4N – Shower	Date Collected:	12/12/2018
Sample ID:	1812-00291.003	Sample Type:	Water
		Time Collected:	8:10 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	4. 4S – COR Sink	Date Collected:	12/12/2018
Sample ID:	1812-00291.004	Sample Type:	Water
		Time Collected:	8:18 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	5. 4 – CCD – 438.01	Date Collected:	12/12/2018
Sample ID:	1812-00291.005	Sample Type:	Water
		Time Collected:	8:25 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	6. 4 – CCD – 440.01	Date Collected:	12/12/2018
Sample ID:	1812-00291.006	Sample Type:	Water
		Time Collected:	8:32 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

FINAL REPORT

Albany Memorial Hospital

Engineering
 600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
 SPL Project ID: 1812-00291
 Project Name: Water Samples For Leg.
 PO Number: 3226-4019
 Sampled By: Thomas R. Poole
 Date Received: 12/13/2018
 Date Final: 12/20/2018

Location:	7. 3N – COR Sink	Date Collected:	12/12/2018
Sample ID:	1812-00291.007	Sample Type:	Water
		Time Collected:	8:40 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	8. 3S – Ex Rm 1	Date Collected:	12/12/2018
Sample ID:	1812-00291.008	Sample Type:	Water
		Time Collected:	8:45 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	9. 2N – COR Sink	Date Collected:	12/12/2018
Sample ID:	1812-00291.009	Sample Type:	Water
		Time Collected:	8:55 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	10. ED XR16	Date Collected:	12/12/2018
Sample ID:	1812-00291.010	Sample Type:	Water
		Time Collected:	9:05 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	11. SG Return	Date Collected:	12/12/2018
Sample ID:	1812-00291.011	Sample Type:	Water
		Time Collected:	9:10 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	12. Main CT	Date Collected:	12/12/2018
Sample ID:	1812-00291.012	Sample Type:	Water
		Time Collected:	10:00 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 12/20/2018
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Albany Memorial Hospital

Engineering
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587
ATTN: Larry Tilton

FINAL REPORT

Account #: 2318
SPL Project ID: 1812-00291
Project Name: Water Samples For Leg.
PO Number: 3226-4019
Sampled By: Thomas R. Poole
Date Received: 12/13/2018
Date Final: 12/20/2018

Approved by: Jack Rihs



Janet E. Stout, Ph.D.
Director, Special Pathogens Laboratory

NOTES

Legionella Environmental Culture Test - New York

- CFU/mL = Colony Forming Units per milliliter of sample
- Limit of detection (LOD): 10 CFU/mL for hot water tanks and non-potable water (cooling towers); 1-10 CFU/mL for potable water. If less than recommended volume is concentrated, sensitivity may be affected. If liter sample is processed, the LOD is <1 CFU/mL.
- Results are reported as Not Detected, Positive, or Uninterpretable.
- Uninterpretable result is due to culture overgrowth by non-Legionella bacteria
- Method: ISO 11731:2017 (E). QA/QC performed on the date processed. Turnaround time is 7-10 days.
- Certified for Legionella culture analysis by New York State Department of Health ELAP. ELAP lab ID no.12024
- Isolates saved upon request. Request must be received 1 week from receipt of report. Additional charges may apply.
- On receipt, SPL lab checks samples for chlorine neutralization by sodium thiosulfate in the collection bottles. Neutralization of other biocides that may be present is not checked.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL.