

FINAL REPORT

Albany Memorial Hospital

Engineering
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1903-00327
Project Name: Legionella Testing
PO Number: 3226-4019
Sampled By: Tom Poole
Date Received: 03/14/2019
Date Final: 03/21/2019

Summary

This summary is provided for your convenience. Complete report on the following pages.

Legionella Environmental Culture Test – New York

Location	Result	Concentration
1. 6N-RM 619	Not Detected	
2. 6th FL WR	Not Detected	
3. 4N Rm 424	Not Detected	
4. 4S Sink	Not Detected	
5. 4CCD 438.01	Not Detected	
6. 4CCD 440.01	Not Detected	
7. 3N Sink	Not Detected	
8. 3S Ex RM 2	Not Detected	
9. 2N Sink	Not Detected	
10. 2S Sink	Not Detected	
11. ED X Rm 16	Not Detected	
12. Main CT	Not Detected	

Approved by: Jack Rihs



Janet E. Stout, Ph.D.
Director, Special Pathogens Laboratory

FINAL REPORT

Albany Memorial Hospital

Engineering
 600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1903-00327
Project Name: Legionella Testing
PO Number: 3226-4019
Sampled By: Tom Poole
Date Received: 03/14/2019
Date Final: 03/21/2019

Location:	1. 6N-RM 619	Date Collected:	03/13/2019
Sample ID:	1903-00327.001	Sample Type:	Water
		Time Collected:	8:00 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	2. 6th FL WR	Date Collected:	03/13/2019
Sample ID:	1903-00327.002	Sample Type:	Water
		Time Collected:	8:10 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	3. 4N Rm 424	Date Collected:	03/13/2019
Sample ID:	1903-00327.003	Sample Type:	Water
		Time Collected:	8:15 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	4. 4S Sink	Date Collected:	03/13/2019
Sample ID:	1903-00327.004	Sample Type:	Water
		Time Collected:	8:20 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	5. 4CCD 438.01	Date Collected:	03/13/2019
Sample ID:	1903-00327.005	Sample Type:	Water
		Time Collected:	8:30 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	6. 4CCD 440.01	Date Collected:	03/13/2019
Sample ID:	1903-00327.006	Sample Type:	Water
		Time Collected:	8:35 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

FINAL REPORT

Albany Memorial Hospital

Engineering
 600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
 SPL Project ID: 1903-00327
 Project Name: Legionella Testing
 PO Number: 3226-4019
 Sampled By: Tom Poole
 Date Received: 03/14/2019
 Date Final: 03/21/2019

Location:	7. 3N Sink	Date Collected:	03/13/2019
Sample ID:	1903-00327.007	Sample Type:	Water
		Time Collected:	8:45 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	8. 3S Ex RM 2	Date Collected:	03/13/2019
Sample ID:	1903-00327.008	Sample Type:	Water
		Time Collected:	8:50 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	9. 2N Sink	Date Collected:	03/13/2019
Sample ID:	1903-00327.009	Sample Type:	Water
		Time Collected:	8:58 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	10. 2S Sink	Date Collected:	03/13/2019
Sample ID:	1903-00327.010	Sample Type:	Water
		Time Collected:	9:05 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	11. ED X Rm 16	Date Collected:	03/13/2019
Sample ID:	1903-00327.011	Sample Type:	Water
		Time Collected:	9:10 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

Location:	12. Main CT	Date Collected:	03/13/2019
Sample ID:	1903-00327.012	Sample Type:	Water
		Time Collected:	10:00 am

Test Requested:	Legionella Environmental Culture Test – New York	Status:	Complete 03/21/2019
Result:	Not Detected		
Volume Examined:	0.1 mL of processed sample		

FINAL REPORT

Albany Memorial Hospital

Engineering
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587
ATTN: Larry Tilton

Account #: 2318
SPL Project ID: 1903-00327
Project Name: Legionella Testing
PO Number: 3226-4019
Sampled By: Tom Poole
Date Received: 03/14/2019
Date Final: 03/21/2019

Approved by: Jack Rihs



Janet E. Stout, Ph.D.
Director, Special Pathogens Laboratory

NOTES

Legionella Environmental Culture Test - New York

- CFU/mL (or swab) = Colony Forming Units per milliliter or swab.
- Limit of detection (LOD): 10 CFU/mL for hot water tanks and non-potable water (cooling towers); 1-10 CFU/mL for potable water. If less than recommended volume is filtered, sensitivity may be affected. If liter sample is processed, the LOD is <1 CFU/mL.
- Results are reported as Not Detected, Positive, or Uninterpretable.
- Uninterpretable result is due to culture overgrowth by non-Legionella bacteria
- Probable identification. Contact laboratory if further identification by 16S sequencing required.
- Method: ISO 11731:2017(E). QA/QC performed on the date processed. Turnaround time is 7-10 d.
- Certified for Legionella culture analysis by New York State Department of Health ELAP. ELAP lab ID no. 12024
- Isolates saved upon request. Request must be received 1 week from receipt of report. Extra charges may apply.
- SPL lab checks samples for chlorine neutralization by sodium thiosulfate. Neutralization of other biocides is not checked.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL.