

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587

Account #: 2318
SPL Project ID: 2002-00699
Project Name: Copper/Silver
PO Number: 3226-4019
Sampled By: TRP
Date Received: 02/27/2020
Date Final: 03/05/2020

Summary

This summary is provided for your convenience. Complete report on the following pages.

Copper/Silver Analysis

Location	Result	Concentration
1. 6N - Rm 619	Complete	Copper: 0.1 mg/L Silver: 0.04 mg/L
2. 6W - WR	Complete	Copper: 0.8 mg/L Silver: 0.08 mg/L
3. 4N - Shower	Complete	Copper: 0.1 mg/L Silver: 0.05 mg/L
4. 4S - CS	Complete	Copper: 0.1 mg/L Silver: 0.05 mg/L
5. 4CCD 438.01	Complete	Copper: 0.3 mg/L Silver: 0.25 mg/L
6. 4CCD 440.01	Complete	Copper: 0.1 mg/L Silver: 0.09 mg/L
7. 3N CS	Complete	Copper: 0.1 mg/L Silver: 0.07 mg/L
8. 3S - Ex Rm 2	Complete	Copper: 0.1 mg/L Silver: 0.06 mg/L
9. 2N - CS	Complete	Copper: 0.1 mg/L Silver: 0.06 mg/L
10. ED - X Rm 16	Complete	Copper: 0.5 mg/L Silver: 0.08 mg/L

Approved by: Marisa Hirsh



Janet E. Stout, Ph.D.
 Director, Special Pathogens Laboratory

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587

Account #: 2318
SPL Project ID: 2002-00699
Project Name: Copper/Silver
PO Number: 3226-4019
Sampled By: TRP
Date Received: 02/27/2020
Date Final: 03/05/2020

Location:	1. 6N - Rm 619	Date Collected:	02/26/2020
Sample ID:	2002-00699.001	Sample Type:	Water
Receipt Temp:		Time Collected:	8:00 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.1 mg/L		
Silver:	0.04 mg/L		
Report Comments:	Copper Ions Below Target Range		

Location:	2. 6W - WR	Date Collected:	02/26/2020
Sample ID:	2002-00699.002	Sample Type:	Water
Receipt Temp:		Time Collected:	8:05 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.8 mg/L		
Silver:	0.08 mg/L		

Location:	3. 4N - Shower	Date Collected:	02/26/2020
Sample ID:	2002-00699.003	Sample Type:	Water
Receipt Temp:		Time Collected:	8:10 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.1 mg/L		
Silver:	0.05 mg/L		
Report Comments:	Copper Ions Below Target Range		

Location:	4. 4S - CS	Date Collected:	02/26/2020
Sample ID:	2002-00699.004	Sample Type:	Water
Receipt Temp:		Time Collected:	8:15 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.1 mg/L		
Silver:	0.05 mg/L		
Report Comments:	Copper Ions Below Target Range		

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587

Account #: 2318
SPL Project ID: 2002-00699
Project Name: Copper/Silver
PO Number: 3226-4019
Sampled By: TRP
Date Received: 02/27/2020
Date Final: 03/05/2020

Location:	5. 4CCD 438.01	Date Collected:	02/26/2020
Sample ID:	2002-00699.005	Sample Type:	Water
Receipt Temp:		Time Collected:	8:25 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.3 mg/L		
Silver:	0.25 mg/L		
Report Comments:	Silver Ions Above Target Range		

Location:	6. 4CCD 440.01	Date Collected:	02/26/2020
Sample ID:	2002-00699.006	Sample Type:	Water
Receipt Temp:		Time Collected:	8:30 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.1 mg/L		
Silver:	0.09 mg/L		
Report Comments:	Copper Ions Below And Silver Ions Above Target Range		

Location:	7. 3N CS	Date Collected:	02/26/2020
Sample ID:	2002-00699.007	Sample Type:	Water
Receipt Temp:		Time Collected:	8:35 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.1 mg/L		
Silver:	0.07 mg/L		
Report Comments:	Copper Ions Below Target Range		

Location:	8. 3S - Ex Rm 2	Date Collected:	02/26/2020
Sample ID:	2002-00699.008	Sample Type:	Water
Receipt Temp:		Time Collected:	8:40 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.1 mg/L		
Silver:	0.06 mg/L		
Report Comments:	Copper Ions Below Target Range		

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587

Account #: 2318
SPL Project ID: 2002-00699
Project Name: Copper/Silver
PO Number: 3226-4019
Sampled By: TRP
Date Received: 02/27/2020
Date Final: 03/05/2020

Location:	9. 2N - CS	Date Collected:	02/26/2020
Sample ID:	2002-00699.009	Sample Type:	Water
Receipt Temp:		Time Collected:	8:45 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.1 mg/L		
Silver:	0.06 mg/L		
Report Comments:	Copper Ions Below Target Range		

Location:	10. ED - X Rm 16	Date Collected:	02/26/2020
Sample ID:	2002-00699.010	Sample Type:	Water
Receipt Temp:		Time Collected:	8:55 am
Test Requested:	Copper/Silver Analysis	Status:	Complete 03/04/2020
Result:	Complete		
Copper:	0.5 mg/L		
Silver:	0.08 mg/L		

Approved by: Marisa Hirsh



Janet E. Stout, Ph.D.
Director, Special Pathogens Laboratory

NOTES

Copper/Silver Analysis

- Analysis performed by SPL. Reference Method - EPA 200.8. Results are for information only and not to be used for compliance reporting.
 - Suggested target ranges for ions: Copper 0.2-0.8 mg/L; Silver 0.01-0.08 mg/L.
- Infect Control Hosp Epidemiol 2011;32(2):166-173

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL. Results apply to the sample as received.