

1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219 P: 412-281-5335 F: 412-281-7445 www.SpecialPathogensLab.com

## **FINAL REPORT**

**Albany Memorial Hospital** 

600 Northern Blvd Albany, NY 12204 P: (518) 471-3015 F: (518) 447-3587

Account #: 2318

SPL Project ID: 2003-00094

Project Name:

PO Number: 3226-4019

Sampled By: **TRP** 

Date Received: 03/05/2020 Date Final: 03/13/2020

## **Summary**

This summary is provided for your convenience. Complete report on the following pages.

### Legionella Environmental Culture Test - New York

Location	Result	Concentration	
1. 6N-619	Not Detected		
2. 6W-WIZ	Not Detected		
3. 4N-Shower	Not Detected		
4. 4S-CS	Not Detected		
5. 4CCD 438.01	Not Detected		
6. 4CCD 440.01	Not Detected		
7. 3N-CS	Not Detected		
8. 3S-EXRM 2	Not Detected		
9. 2S-CS	Not Detected		
10. ED XRM 16	Not Detected		
11. Main Drain	Not Detected		
12. Main CT	Positive	40 CFU/mL	Legionella species, not pneumophila

Approved by: Marisa Hirsh

Janet E. Stout, Ph.D.

Director, Special Pathogens Laboratory



Date Collected:

Date Collected:

03/04/2020

1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219 P: 412-281-5335 F: 412-281-7445 www.SpecialPathogensLab.com

## **FINAL REPORT**

**Albany Memorial Hospital** 

600 Northern Blvd Albany, NY 12204 P: (518) 471-3015

F: (518) 447-3587

Account #: 2318

SPL Project ID: 2003-00094

Project Name:

PO Number: 3226-4019

Sampled By: **TRP** 

Date Received: 03/05/2020 Date Final: 03/13/2020

1. 6N-619 Date Collected: 03/04/2020 Location:

2003-00094.001 Sample Type: Water Sample ID: Time Collected: 7:45 am Receipt Temp:

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result: **Not Detected** 

Volume Examined: 0.1 mL of processed sample

2. 6W-WIZ Date Collected: 03/04/2020 Location:

Sample ID: 2003-00094.002 Sample Type: Water 7:50 am Time Collected: Receipt Temp:

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result: **Not Detected** 

Location:

Volume Examined:

Location:

Volume Examined: 0.1 mL of processed sample

2003-00094.003 Water Sample Type: Sample ID:

Receipt Temp: Time Collected: 7:55 am Status: Complete 03/13/2020

Test Requested: Legionella Environmental Culture Test - New York

Result: **Not Detected** 

Volume Examined: 0.1 mL of processed sample

5. 4CCD 438.01

0.1 mL of processed sample

3. 4N-Shower

03/04/2020 Location: 4. 4S-CS Date Collected:

2003-00094.004 Water Sample Type: Sample ID: 7:57 am Time Collected: Receipt Temp:

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result:

**Not Detected** 

03/04/2020

2003-00094.005 Water Sample Type: Sample ID:

8:00 am Receipt Temp: Time Collected:

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result: **Not Detected** 

Volume Examined: 0.1 mL of processed sample



1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219 P: 412-281-5335 F: 412-281-7445 www.SpecialPathogensLab.com

## **FINAL REPORT**

**Albany Memorial Hospital** 

600 Northern Blvd Albany, NY 12204 P: (518) 471-3015 F: (518) 447-3587

Account #: 2318

SPL Project ID: 2003-00094

Project Name:

PO Number: 3226-4019

Sampled By: **TRP** 

Date Received: 03/05/2020 Date Final: 03/13/2020

6. 4CCD 440.01 Date Collected: 03/04/2020 Location:

2003-00094.006 Sample Type: Water Sample ID: Time Collected: 8:01 am Receipt Temp:

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result: **Not Detected** 

Volume Examined: 0.1 mL of processed sample

Date Collected: 03/04/2020 Location: 7. 3N-CS

Sample ID: 2003-00094.007 Sample Type: Water 8:05 am Time Collected: Receipt Temp:

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result: **Not Detected** 

Volume Examined: 0.1 mL of processed sample

0.1 mL of processed sample

8. 3S-EXRM 2 Date Collected: 03/04/2020 Location: 2003-00094.008 Water

Sample Type: Sample ID: Receipt Temp: Time Collected: 8:08 am

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result: **Not Detected** 

Volume Examined: 0.1 mL of processed sample

03/04/2020 Location: 9. 2S-CS Date Collected:

2003-00094.009 Water Sample Type: Sample ID: Time Collected: 8:10 am

Receipt Temp: Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result:

**Not Detected** 

Volume Examined:

03/04/2020 Location: 10. ED XRM 16 Date Collected: 2003-00094.010 Water

Sample Type: Sample ID: 8:15 am Receipt Temp: Time Collected:

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result: **Not Detected** 

Volume Examined: 0.1 mL of processed sample



1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219
P: 412-281-5335 F: 412-281-7445
www.SpecialPathogensLab.com

## **FINAL REPORT**

**Albany Memorial Hospital** 

600 Northern Blvd Albany, NY 12204 P: (518) 471-3015 F: (518) 447-3587 Account #: 2318

SPL Project ID: 2003-00094

Project Name:

PO Number: 3226-4019

Sampled By: TRP

Date Received: 03/05/2020 Date Final: 03/13/2020

Location: 11. Main Drain Date Collected: 03/04/2020

Sample ID: 2003-00094.011 Sample Type: Water
Receipt Temp: Time Collected: 8:20 am

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result: Not Detected

Volume Examined: 0.1 mL of processed sample

Location: 12. Main CT Date Collected: 03/04/2020

Sample ID: 2003-00094.012 Sample Type: Water
Receipt Temp: Time Collected: 8:25 am

Test Requested: Legionella Environmental Culture Test - New York Status: Complete 03/13/2020

Result: **Positive**Concentration: 40 CFU/mL

Species: Legionella species, not pneumophila

Volume Examined: 0.1 mL of processed sample

Approved by: Marisa Hirsh

Janet E. Stout, Ph.D.

Director, Special Pathogens Laboratory

#### **NOTES**

#### Legionella Environmental Culture Test - New York

- -CFU/mL (or swab) = Colony Forming Units per milliliter or swab.
- -Limit of detection (LOD): 10 CFU/mL for hot water tanks and non-potable water (cooling towers);1-10 CFU/mL for potable water. If less than recommended volume is filtered, sensitivity may be affected. If liter sample is processed, the LOD is <1 CFU/mL.
- -Results are reported as Not Detected, Positive, or Uninterpretable.
- -Uninterpretable result is due to culture overgrowth by non-Legionella bacteria
- -Probable identification. Contact laboratory if further identification by 16S sequencing required.
- -Method: ISO 11731:2017(E).QA/QC performed on the date processed. Turnaround time is 7-10 d.
- -Certified for Legionella culture analysis by New York State Department of Health ELAP.ELAP lab ID no.12024
- -Isolates saved upon request. Request must be received 1 week from receipt of report. Extra charges may apply.
- -SPL lab checks samples for chlorine neutralization by sodium thiosulfate. Neutralization of other biocides is not checked.



1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219
P: 412-281-5335 F: 412-281-7445
www.SpecialPathogensLab.com

# **FINAL REPORT**

**Albany Memorial Hospital** 

600 Northern Blvd Albany, NY 12204 P: (518) 471-3015 F: (518) 447-3587 Account #: 2318

SPL Project ID: 2003-00094

Project Name:

PO Number: 3226-4019

Sampled By: TRP

Date Received: 03/05/2020 Date Final: 03/13/2020

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL. Results apply to the sample as received.