

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587

Account #: 2318
SPL Project ID: 2010-00103
Project Name: Legionella
PO Number: 3226-4019
Sampled By: TRP
Date Received: 10/02/2020
Date Final: 10/09/2020

Summary

This summary is provided for your convenience. Complete report on the following pages.

Environmental Culture Test-Legionella

Location	Result	Concentration	Species
1. 6N-619	Not Detected		
2. 6W-WR	Not Detected		
3. 5N-515	Not Detected		
4. 5S-509	Not Detected		
5. 4N-415	Not Detected		
6. 4S-CS	Not Detected		
7. 4CCD-438.01	Not Detected		
8. 4CCD-440.01	Not Detected		
9. 3N-CS	Not Detected		
10. 3S-Ex Rm 2	Not Detected		
11. 2N-CS	Not Detected		
12. 2S-CS	Not Detected		
13. ED-X Rm 16	Not Detected		
14. Pump House CW Main	Not Detected		
15. PACU - Clean Utility	Not Detected		
16. OR-ARN	Not Detected		
17. Kitchen Pot Sink	Not Detected		
18. Hot Water Main	Not Detected		
19. HW Return	Not Detected		
20. SG Bath Room	Not Detected		



FINAL REPORT

Albany Memorial Hospital
600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587

Account #: 2318
SPL Project ID: 2010-00103
Project Name: Legionella
PO Number: 3226-4019
Sampled By: TRP
Date Received: 10/02/2020
Date Final: 10/09/2020

Approved by: Heidi Jones

A handwritten signature in blue ink, appearing to read 'Janet Stout'.

Janet E. Stout, Ph.D.
Laboratory Director, Special Pathogens Laboratory

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587

Account #: 2318
SPL Project ID: 2010-00103
Project Name: Legionella
PO Number: 3226-4019
Sampled By: TRP
Date Received: 10/02/2020
Date Final: 10/09/2020

Location:	1. 6N-619	Date Collected:	10/01/2020
Sample ID:	2010-00103.001	Sample Type:	Water
Receipt Temp:		Time Collected:	5:45 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	2. 6W-WR	Date Collected:	10/01/2020
Sample ID:	2010-00103.002	Sample Type:	Water
Receipt Temp:		Time Collected:	5:48 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	3. 5N-515	Date Collected:	10/01/2020
Sample ID:	2010-00103.003	Sample Type:	Water
Receipt Temp:		Time Collected:	5:50 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	4. 5S-509	Date Collected:	10/01/2020
Sample ID:	2010-00103.004	Sample Type:	Water
Receipt Temp:		Time Collected:	5:53 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	5. 4N-415	Date Collected:	10/01/2020
Sample ID:	2010-00103.005	Sample Type:	Water
Receipt Temp:		Time Collected:	5:56 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587

Account #: 2318
SPL Project ID: 2010-00103
Project Name: Legionella
PO Number: 3226-4019
Sampled By: TRP
Date Received: 10/02/2020
Date Final: 10/09/2020

Location:	6. 4S-CS	Date Collected:	10/01/2020
Sample ID:	2010-00103.006	Sample Type:	Water
Receipt Temp:		Time Collected:	6:03 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	7. 4CCD-438.01	Date Collected:	10/01/2020
Sample ID:	2010-00103.007	Sample Type:	Water
Receipt Temp:		Time Collected:	6:10 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	8. 4CCD-440.01	Date Collected:	10/01/2020
Sample ID:	2010-00103.008	Sample Type:	Water
Receipt Temp:		Time Collected:	6:20 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	9. 3N-CS	Date Collected:	10/01/2020
Sample ID:	2010-00103.009	Sample Type:	Water
Receipt Temp:		Time Collected:	6:30 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	10. 3S-Ex Rm 2	Date Collected:	10/01/2020
Sample ID:	2010-00103.010	Sample Type:	Water
Receipt Temp:		Time Collected:	6:40 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587

Account #: 2318
SPL Project ID: 2010-00103
Project Name: Legionella
PO Number: 3226-4019
Sampled By: TRP
Date Received: 10/02/2020
Date Final: 10/09/2020

Location:	11. 2N-CS	Date Collected:	10/01/2020
Sample ID:	2010-00103.011	Sample Type:	Water
Receipt Temp:		Time Collected:	6:45 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	12. 2S-CS	Date Collected:	10/01/2020
Sample ID:	2010-00103.012	Sample Type:	Water
Receipt Temp:		Time Collected:	6:50 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	13. ED-X Rm 16	Date Collected:	10/01/2020
Sample ID:	2010-00103.013	Sample Type:	Water
Receipt Temp:		Time Collected:	6:55 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	14. Pump House CW Main	Date Collected:	10/01/2020
Sample ID:	2010-00103.014	Sample Type:	Water
Receipt Temp:		Time Collected:	7:00 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	15. PACU - Clean Utility	Date Collected:	10/01/2020
Sample ID:	2010-00103.015	Sample Type:	Water
Receipt Temp:		Time Collected:	7:05 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
 Albany, NY 12204
 P: (518) 471-3015
 F: (518) 447-3587

Account #: 2318
SPL Project ID: 2010-00103
Project Name: Legionella
PO Number: 3226-4019
Sampled By: TRP
Date Received: 10/02/2020
Date Final: 10/09/2020

Location:	16. OR-ARN	Date Collected:	10/01/2020
Sample ID:	2010-00103.016	Sample Type:	Water
Receipt Temp:		Time Collected:	7:10 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	17. Kitchen Pot Sink	Date Collected:	10/01/2020
Sample ID:	2010-00103.017	Sample Type:	Water
Receipt Temp:		Time Collected:	7:15 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	18. Hot Water Main	Date Collected:	10/01/2020
Sample ID:	2010-00103.018	Sample Type:	Water
Receipt Temp:		Time Collected:	7:20 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	19. HW Return	Date Collected:	10/01/2020
Sample ID:	2010-00103.019	Sample Type:	Water
Receipt Temp:		Time Collected:	7:25 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

Location:	20. SG Bath Room	Date Collected:	10/01/2020
Sample ID:	2010-00103.020	Sample Type:	Water
Receipt Temp:		Time Collected:	7:30 am
Test Requested:	Environmental Culture Test-Legionella	Status:	Complete 10/09/2020
Result:	Not Detected		

FINAL REPORT

Albany Memorial Hospital

600 Northern Blvd
Albany, NY 12204
P: (518) 471-3015
F: (518) 447-3587

Account #: 2318
SPL Project ID: 2010-00103
Project Name: Legionella
PO Number: 3226-4019
Sampled By: TRP
Date Received: 10/02/2020
Date Final: 10/09/2020

Approved by: Heidi Jones



Janet E. Stout, Ph.D.
Laboratory Director, Special Pathogens Laboratory

NOTES

Environmental Culture Test-Legionella

- CFU/mL (or swab)=Colony Forming Units per milliliter or swab.
- The limit of detection (LOD)* is approximately - 0.5 -10 CFU/mL for Potable Water; 10 CFU/mL for Non-Potable Water (Cooling Towers); 1-10 CFU/mL for Hot Water Tanks; 20 CFU/swab for Swabs.
- * Sensitivity (LOD) may be affected if less than recommended sample volume is submitted for testing and if high concentration of non-Legionella bacteria are present in the sample. LOD values are mathematically derived according to the sample type, volume, and process.
- Results are reported as Not Detected, Positive, or Uninterpretable.
- Uninterpretable result is due to culture overgrowth by non-Legionella bacteria.
- Probable identification. Contact laboratory if further identification by 16S sequencing required.
- Method: ISO 11731:2017 (E). QA/QC performed on the date processed. Turnaround time is 7-10 days
- Samples should be analyzed within 2 days of collection.
- Accredited by the American Association for Laboratory Accreditation (Cert. No. 2847.01) and ELITE certified.
- Isolates saved upon request. Request must be received 1 week from receipt of report. Extra charges may apply.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL. Results apply to the sample as received.