



## FINAL REPORT

### Albany Memorial Hospital

600 Northern Blvd

Albany, NY 12204

P: (518) 471-3015

**Account #:** 2318

SPL Project ID: 2101-00103

Project Name: Legionella Testing

PO Number: 3226-4019

Sampled By: KM/JW

Date Received: 01/07/2021

Date Final: 01/14/2021

## Summary

This summary is provided for your convenience. Complete report on the following pages.

### Legionella Environmental Culture Test - New York

Location	Result	Concentration
1. 6N Rm 619	Not Detected	
2. 6W Waiting Room	Not Detected	
3. 5N 516	Not Detected	
4. 5S Rm 509	Not Detected	
5. 4N Hall	Not Detected	
6. 4S Rm 405	Not Detected	
7. Rm 438.01	Not Detected	
8. Rm 440.01	Not Detected	
9. 3N Hall Sink	Not Detected	
10. 3S Rm 6	Not Detected	
11. 2S Hall Sink	Not Detected	
12. 2N Hall Sink	Not Detected	
13. SG Hot Water Return	Not Detected	
14. HW Heater	Not Detected	
15. SG Rest Rm	Not Detected	
16. ED Across 16	Not Detected	
17. Pump House	Not Detected	
18. Kitchen Pot Sink	Not Detected	
19. Across X Ray 1	Not Detected	
20. Across X Ray 2	Not Detected	



## THE LEGIONELLA EXPERTS®

1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219

P: 412-281-5335 F: 412-281-7445

[www.SpecialPathogensLab.com](http://www.SpecialPathogensLab.com)

## FINAL REPORT

### Albany Memorial Hospital

600 Northern Blvd

Albany, NY 12204

P: (518) 471-3015

Account #: 2318

SPL Project ID: 2101-00103

Project Name: Legionella Testing

PO Number: 3226-4019

Sampled By: KM/JW

Date Received: 01/07/2021

Date Final: 01/14/2021

Approved by: Marisa Hirsh

A handwritten signature in blue ink, appearing to read "Janet Stout", is written over a horizontal line.

Janet E. Stout, Ph.D.

Laboratory Director, Special Pathogens Laboratory



## FINAL REPORT

### Albany Memorial Hospital

600 Northern Blvd  
Albany, NY 12204  
P: (518) 471-3015

**Account #:** 2318  
**SPL Project ID:** 2101-00103  
**Project Name:** Legionella Testing  
**PO Number:** 3226-4019  
**Sampled By:** KM/JW  
**Date Received:** 01/07/2021  
**Date Final:** 01/14/2021

Location:	<b>1. 6N Rm 619</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.001	Sample Type:	Water
Receipt Temp:		Time Collected:	8:45 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>2. 6W Waiting Room</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.002	Sample Type:	Water
Receipt Temp:		Time Collected:	8:50 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>3. 5N 516</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.003	Sample Type:	Water
Receipt Temp:		Time Collected:	9:00 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>4. 5S Rm 509</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.004	Sample Type:	Water
Receipt Temp:		Time Collected:	9:02 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>5. 4N Hall</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.005	Sample Type:	Water
Receipt Temp:		Time Collected:	9:05 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		



## FINAL REPORT

### Albany Memorial Hospital

600 Northern Blvd  
Albany, NY 12204  
P: (518) 471-3015

**Account #:** 2318  
**SPL Project ID:** 2101-00103  
**Project Name:** Legionella Testing  
**PO Number:** 3226-4019  
**Sampled By:** KM/JW  
**Date Received:** 01/07/2021  
**Date Final:** 01/14/2021

Location:	<b>6. 4S Rm 405</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.006	Sample Type:	Water
Receipt Temp:		Time Collected:	9:10 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>7. Rm 438.01</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.007	Sample Type:	Water
Receipt Temp:		Time Collected:	9:12 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>8. Rm 440.01</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.008	Sample Type:	Water
Receipt Temp:		Time Collected:	9:15 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>9. 3N Hall Sink</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.009	Sample Type:	Water
Receipt Temp:		Time Collected:	9:20 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>10. 3S Rm 6</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.010	Sample Type:	Water
Receipt Temp:		Time Collected:	9:22 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		



## FINAL REPORT

### Albany Memorial Hospital

600 Northern Blvd  
Albany, NY 12204  
P: (518) 471-3015

**Account #:** 2318  
**SPL Project ID:** 2101-00103  
**Project Name:** Legionella Testing  
**PO Number:** 3226-4019  
**Sampled By:** KM/JW  
**Date Received:** 01/07/2021  
**Date Final:** 01/14/2021

Location:	<b>11. 2S Hall Sink</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.011	Sample Type:	Water
Receipt Temp:		Time Collected:	9:25 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>12. 2N Hall Sink</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.012	Sample Type:	Water
Receipt Temp:		Time Collected:	9:28 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>13. SG Hot Water Return</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.013	Sample Type:	Water
Receipt Temp:		Time Collected:	9:32 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>14. HW Heater</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.014	Sample Type:	Water
Receipt Temp:		Time Collected:	9:31 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		

Location:	<b>15. SG Rest Rm</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.015	Sample Type:	Water
Receipt Temp:		Time Collected:	9:36 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		



## FINAL REPORT

### Albany Memorial Hospital

600 Northern Blvd  
Albany, NY 12204  
P: (518) 471-3015

**Account #:** 2318  
**SPL Project ID:** 2101-00103  
**Project Name:** Legionella Testing  
**PO Number:** 3226-4019  
**Sampled By:** KM/JW  
**Date Received:** 01/07/2021  
**Date Final:** 01/14/2021

Location:	<b>16. ED Across 16</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.016	Sample Type:	Water
Receipt Temp:		Time Collected:	9:40 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		
Location:	<b>17. Pump House</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.017	Sample Type:	Water
Receipt Temp:		Time Collected:	9:45 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		
Location:	<b>18. Kitchen Pot Sink</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.018	Sample Type:	Water
Receipt Temp:		Time Collected:	9:51 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		
Location:	<b>19. Across X Ray 1</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.019	Sample Type:	Water
Receipt Temp:		Time Collected:	10:10 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		
Location:	<b>20. Across X Ray 2</b>	Date Collected:	01/06/2021
Sample ID:	2101-00103.020	Sample Type:	Water
Receipt Temp:		Time Collected:	10:15 am
Test Requested:	Legionella Environmental Culture Test - New York	Status:	Complete 01/14/2021
Result:	<b>Not Detected</b>		
Volume Examined:	0.1 mL of processed sample		



## FINAL REPORT

**Albany Memorial Hospital**

600 Northern Blvd

Albany, NY 12204

P: (518) 471-3015

**Account #: 2318**

SPL Project ID: 2101-00103

Project Name: Legionella Testing

PO Number: 3226-4019

Sampled By: KM/JW

Date Received: 01/07/2021

Date Final: 01/14/2021

Approved by: Marisa Hirsh

Janet E. Stout, Ph.D.

Laboratory Director, Special Pathogens Laboratory

## NOTES

### Legionella Environmental Culture Test - New York

-CFU/mL (or swab) = Colony Forming Units per milliliter or swab.

- The limit of detection (LOD)\* is approximately- 0.5-10 CFU/mL for Potable Water; 10 CFU/mL for Non-Potable Water (Cooling Towers); 1-10 CFU/mL for Hot Water Tanks; 20 CFU/swab for Swabs.

\* Sensitivity (LOD) may be affected if less than recommended sample volume is submitted for testing and if high concentration of non-Legionella bacteria are present in the sample. LOD values are mathematically derived according to the sample type, volume, and process.

-Results are reported as Not Detected, Positive, or Uninterpretable.

-Uninterpretable result is due to culture overgrowth by non-Legionella bacteria.

-Probable identification. Contact laboratory if further identification by 16S sequencing required.

-Method: ISO 11731:2017(E).QA/QC performed on the date processed. Turnaround time is 7-10 days.

- Samples should be analyzed within 2 days of collection.

- Accredited for Legionella culture analysis by New York State Department of Health ELAP (ELAP Lab ID No.12024) and State of Connecticut Department of Public Health ( Reg No. PH-0125)

-Isolates saved upon request. Request must be received 1 week from receipt of report. Extra charges may apply.

-SPL lab checks samples for chlorine neutralization by sodium thiosulfate. Neutralization of other biocides is not checked.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL. Results apply to the sample as received.