## **Corrective Maintenance Work Order**

Print Date: 10/6/2020 **HIGH LEGIONELLA LEVEL - 6W WAITING ROOM WO#:** 332423 Safety Incident #: Account: 3011 - Wound Care **Type:** Corrective Maintenance Date Orig: 9/18/2020 Site: Priority: High Time Orig: 14:27 **Building:** Status: ACTIVE Date Avail: Location: Sub-Status: ISSUED **Date Needed:** Skill: Boiler Operator Req Name: Req Phone: Req Pager: Req Remarks: **Assignments** Resource # **Resource Name Resource Phone** rhfw9621 Poole, Thomas 518-471-3619 42354 Wisenburn, John 518-471-3144 **Time Charges** Resource # **Resource Name** Hours **Date** Cost 42354 John Wisenburn 10/1/2020 0.50000000 \$12.50 42354 John Wisenburn 9/30/2020 0.50000000 \$12.50 42354 John Wisenburn 9/29/2020 0.50000000 \$12.50 42354 John Wisenburn 9/28/2020 0.50000000 \$12.50 42354 John Wisenburn 9/21/2020 1.00000000 \$25.00 rhfw9621 Thomas Poole 9/23/2020 0.50000000 \$11.25 rhfw9621 Thomas Poole 9/22/2020 1.00000000 \$22.50 0.17000000 rhfw9621 Thomas Poole 9/18/2020 \$3.83 **Problem Code:** Cause Code: Total Time: 4.67000000 Item Code: Labor Cost: \$112.58 **Action Code:** Material Cost: \$0.00 Total WO Cost: \$112.58 Date: Completed By: \_ FLUSHED SINKS - TOOK CHLORINE DIOXIDE READINGS Comments: (TC 09/22/20209/22/2020 10:03:14 AM, Thomas Poole) FLUSHED FIXTURES (6) FROM CORRECTIVE WORK ORDERS PLUS ADDITIONAL (14) IN PREPARATION FOR LEGIONELLA TESTING SCHEDULED FOR 11-01-2020. TRPoole (TC 09/23/20209/23/2020 2:16:39 PM, Thomas Poole) CLEANED FAUCETS WITH LIME AWAY & DISINFECTANT CLEANER - TRPoole (TC 09/22/2020 07:23:04 AM, Wisenburn, John) replaced faucet, cleaned up area (TC 09/21/2020 07:23:04 AM, Wisenburn, John)

TMS Reporting by Four Rivers Software Systems, Inc.

flushed hot side

replaced faucet, cleaned up area

(TC 09/28/2020 09:00:48 AM, Wisenburn, John)