

Corrective Maintenance Work Order

Print Date: 10/6/2020

WO#:	332425	HIGH LEGIONELLA LEVEL - 4 CCD - 440.01
-------------	---------------	---

Safety Incident #:

Account: 1065 - CCD	Type: Corrective Maintenance	Date Orig: 9/18/2020
Site:	Priority: High	Time Orig: 14:30
Building:	Status: ACTIVE	Date Avail:
Location:	Sub-Status: ISSUED	Date Needed:
		Skill: Boiler Operator

Req Name: _____ **Req Phone:** _____ **Req Pager:** _____
Req Remarks: _____

Assignments

Resource #	Resource Name	Resource Phone
rhfw9621	Poole, Thomas	518-471-3619
42354	Wisensburn, John	518-471-3144

Time Charges

Resource #	Resource Name	Date	Hours	Cost
42354	John Wisensburn	10/1/2020	0.50000000	\$12.50
42354	John Wisensburn	9/30/2020	0.50000000	\$12.50
42354	John Wisensburn	9/29/2020	0.50000000	\$12.50
42354	John Wisensburn	9/28/2020	0.50000000	\$12.50
42354	John Wisensburn	9/21/2020	2.00000000	\$50.00
rhfw9621	Thomas Poole	9/23/2020	0.50000000	\$11.25
rhfw9621	Thomas Poole	9/22/2020	1.00000000	\$22.50
rhfw9621	Thomas Poole	9/18/2020	0.17000000	\$3.83

Problem Code:	Cause Code:	Total Time: 5.67000000
Action Code:	Item Code:	Labor Cost: \$137.58
		Material Cost: \$0.00
		Total WO Cost: \$137.58

Completed By: _____ **Date:** _____

Comments: FLUSHED SINKS - TOOK CHLORINE DIOXIDE READINGS
 (TC 09/22/2020 10:03:14 AM, Thomas Poole)
 FLUSHED FIXTURES (6) FROM CORRECTIVE WORK ORDERS PLUS ADDITIONAL (14) IN PREPARATION FOR LEGIONELLA TESTING SCHEDULED FOR 11-01-2020. TRPoole

 (TC 09/23/2020 2:16:39 PM, Thomas Poole)
 CLEANED FAUCETS WITH LIME AWAY & DISINFECTANT CLEANER - TRPoole

 (TC 09/25/2020 07:13:56 AM, Wisensburn, John)
 removed existing caulk around counter top , removed counter top , faucet , replaced trap and cleared drain , installed faucet reinstalled counter top ,caulked and painted wall

 (TC 09/21/2020 07:13:56 AM, Wisensburn, John)
 removed existing caulk around counter top , removed counter top , faucet , replaced trap and cleared drain , installed faucet reinstalled counter top ,caulked and painted wall

Corrective Maintenance Work Order

Print Date: 10/6/2020

WO#:	332425	HIGH LEGIONELLA LEVEL - 4 CCD - 440.01
-------------	---------------	---

(TC 09/28/2020 08:54:50 AM, Wisenburn, John)
flushed hot side

(TC 09/29/2020 08:55:29 AM, Wisenburn, John)
flushed hot side

(TC 09/30/2020 08:56:11 AM, Wisenburn, John)
flushed hot side

(TC 10/01/2020 08:56:50 AM, Wisenburn, John)
flushed hot side