Corrective Maintenance Work Order

Print Date: 10/6/2020

WO#: 332427 HIGH LEGIONELLA LEVEL - 4 CCD - 438.01

Safety Incident #:

Account: 1065 - CCD Type: Corrective Maintenance Date Orig: 9/18/2020

Site: Priority: High Time Orig: 14:31

Building: Status: ACTIVE Date Avail:

Location: Sub-Status: ISSUED Date Needed:

Skill: Boiler Operator

Req Name: Req Phone: Req Pager:

Req Remarks:

Assignments					
Resource #	Resource Name	Resource Phone			
rhfw9621	Poole, Thomas	518-471-3619			
42354	Wisenburn, John	518-471-3144			

Time Charges							
Resource #	Resource Name	Date	Hours	Cost			
42354	John Wisenburn	10/1/2020	0.50000000	\$12.50			
42354	John Wisenburn	9/30/2020	0.50000000	\$12.50			
42354	John Wisenburn	9/29/2020	0.50000000	\$12.50			
42354	John Wisenburn	9/28/2020	0.50000000	\$12.50			
42354	John Wisenburn	9/21/2020	2.50000000	\$62.50			
rhfw9621	Thomas Poole	9/23/2020	0.50000000	\$11.25			
rhfw9621	Thomas Poole	9/22/2020	1.00000000	\$22.50			
rhfw9621	Thomas Poole	9/18/2020	0.17000000	\$3.83			

Problem Code: Cause Code: Total Time: 6.17000000

Action Code: Item Code: Labor Cost: \$150.08

Material Cost: \$0.00

Total WO Cost: \$150.08

Completed By: ______ Date: ____

Comments: FLUSHED SINKS - TOOK CHLORINE DIOXIDE READINGS

(TC 09/22/20209/22/2020 10:03:14 AM, Thomas Poole)

FLUSHED FIXTURES (6) FROM CORRECTIVE WORK ORDERS PLUS ADDITIONAL (14) IN PREPARATION FOR

LEGIONELLA TESTING SCHEDULED FOR 11-01-2020. TRPoole

(TC 09/23/20209/23/2020 2:16:39 PM, Thomas Poole)

CLEANED FAUCETS WITH LIME AWAY & DISINFECTANT CLEANER - TRPoole

(TC 09/25/2020 07:07:28 AM, Wisenburn, John)

removed counter top, caulking and faucet repaired drain, installed faucet and counter top checked for leaks and cleaned up area

(TC 09/21/2020 07:07:28 AM, Wisenburn, John)

removed counter top, caulking and faucet repaired drain, installed faucet and counter top checked for leaks and cleaned up area

TMS Reporting by Four Rivers Software Systems, Inc.

Corrective Maintenance Work Order

Print Date: 10/6/2020

WO#: 332427 HIGH LEGIONELLA LEVEL - 4 CCD - 438.01

(TC 10/01/2020 08:51:42 AM, Wisenburn, John) flush hot side

(TC 09/28/2020 08:51:42 AM, Wisenburn, John) flush hot side

(TC 09/30/2020 08:53:17 AM, Wisenburn, John) flushed hot side

(TC 10/01/2020 08:54:02 AM, Wisenburn, John) flushed hot side