



# Corrective Maintenance Work Order

Print Date: 10/6/2020

**WO#:**

**332428**

**HIGH LEGIONELLA LEVEL - 3N - CORRIDOR SINK**

(TC 09/30/2020 07:48:03 AM, Wisenburn, John)  
flushed hot water

(TC 09/29/2020 07:48:03 AM, Wisenburn, John)  
flushed hot water

(TC 09/30/2020 08:41:59 AM, Wisenburn, John)  
flushed hot side

(TC 09/28/2020 07:48:03 AM, Wisenburn, John)  
flushed hot water

(TC 09/29/2020 08:41:59 AM, Wisenburn, John)  
flushed hot side

(TC 09/30/2020 08:44:37 AM, Wisenburn, John)  
flushed hot side

(TC 10/01/2020 08:50:55 AM, Wisenburn, John)  
flushed hot side