Corrective Maintenance Work Order

Print Date: 10/6/2020

WO#: 332429 HIGH LEGIONELLA LEVEL - 3S - EXAM ROOM 2

Safety Incident #:

Account: 3005 - Pelvic Center Type: Corrective Maintenance Date Orig: 9/18/2020

Site: Priority: High Time Orig: 14:33

Building: Status: ACTIVE Date Avail:

Location: Sub-Status: ISSUED Date Needed:

Skill: Boiler Operator

Req Name: Req Phone: Req Pager:

Req Remarks:

Assignments						
Resource #	Resource Name	Resource Phone				
rhfw9621	Poole, Thomas	518-471-3619				
42354	Wisenburn, John	518-471-3144				

Time Charges							
Resource #	Resource Name	Date	Hours	Cost			
42354	John Wisenburn	10/1/2020	0.50000000	\$12.50			
42354	John Wisenburn	9/30/2020	0.50000000	\$12.50			
42354	John Wisenburn	9/29/2020	0.50000000	\$12.50			
42354	John Wisenburn	9/28/2020	0.50000000	\$12.50			
42354	John Wisenburn	9/21/2020	1.00000000	\$25.00			
rhfw9621	Thomas Poole	9/23/2020	0.50000000	\$11.25			
rhfw9621	Thomas Poole	9/22/2020	1.00000000	\$22.50			
rhfw9621	Thomas Poole	9/18/2020	0.17000000	\$3.83			

Problem Code: Cause Code: Total Time: 4.67000000

Action Code: Item Code: Labor Cost: \$112.58

Material Cost: \$0.00

Total WO Cost: \$112.58

Completed By: ______ Date: ____

Comments: FLUSHED SINKS - TOOK CHLORINE DIOXIDE READINGS

(TC 09/22/20209/22/2020 10:03:14 AM, Thomas Poole)

FLUSHED FIXTURES (6) FROM CORRECTIVE WORK ORDERS PLUS ADDITIONAL (14) IN PREPARATION FOR

LEGIONELLA TESTING SCHEDULED FOR 11-01-2020. TRPoole

(TC 09/23/20209/23/2020 2:16:39 PM, Thomas Poole)

CLEANED FAUCETS WITH LIME AWAY & DISINFECTANT CLEANER - TRPoole

(TC 09/21/2020 02:06:48 PM, Wisenburn, John)

removed old Koehler faucet installed a Chicago 8" center removed old caulking reinstalled sink and caulked around base cleaned up area

(TC 09/30/2020 07:52:10 AM, Wisenburn, John)

flushed hot side

Corrective Maintenance Work Order

Print Date: 10/6/2020

WO#:

332429

HIGH LEGIONELLA LEVEL - 3S - EXAM ROOM 2

(TC 09/29/2020 07:52:10 AM, Wisenburn, John) flushed hot side

(TC 09/30/2020 08:40:28 AM, Wisenburn, John) flushed hot side

(TC 09/28/2020 07:52:10 AM, Wisenburn, John) flushed hot side

(TC 09/29/2020 08:40:28 AM, Wisenburn, John) flushed hot side

(TC 09/30/2020 08:48:33 AM, Wisenburn, John) flushed hot side

(TC 10/01/2020 08:49:49 AM, Wisenburn, John) flushed hot side